

Cooperative System Peak Calculation:

Base System Peak (MW):	587.76
Less any CSP or MBR Service (MW):	0
Total System Peak Available for NEM (MW):	587.76

	Residential	Non-Residential	Non-Jurisdictional
SCC Cap Limits, By Category:	2.0%	1.0%	2.0%
Allowable Generation (MW):	11.76	5.88	11.76

NEM Systems Installed:

	Residential	Non-Residential	Non-Jurisdictional
Currently Installed (kW):	4157.55	3052.26	1091.27
Cap Space Used:	35%	52%	9%

NEM Capacity Available:

	Residential	Non-Residential	Non-Jurisdictional
Install Capacity Available (kW):	7597.63	2825.33	10663.91
Cap Space Available:	65%	48%	91%

Last Updated:

7/1/2020

For Additional Information, Contact:

Netmetering@svec.coop

Notes:

“System peak” is the highest peak (based on the noncoincident peak of the Cooperative or the coincident peak of all of the Cooperative’s customers) of the past three years listed in Part O, Line 20 of Form 7 (Financial And Operating Report – Electric Distribution) filed with the U.S. Department of Agriculture’s Rural Utilities Service (RUS), or an equivalent form if the Cooperative is not an RUS borrower, less any portion of the Cooperative’s total load that is served by a competitive service provider (CSP) or by a market-based rate (MBR).

The Cooperative shall abide by 20 VAC 5-315-40(B) in regard to its administration of and calculation of its caps.